

IAPMO OCEANIA

7-11 Fullard Road, Narre Warren, Victoria 3805, Australia /info@iapmooceania.org



CERTIFICATE OF CONFORMITY

IAPMO Oceania hereby grants to:

Acu-Tech Pty Ltd

A.B.N.: 68 626 756 223

119 Kevin Road, Maddigton, Perth, WA 6109 Australia

Email: richard.m@acu-tech.com.au

the right to use the WaterMark in accordance with the ABCB Manual for the WaterMark Certification Scheme;– Australian Standards; WaterMark Technical Specifications; and the Plumbing Code of Australia; only in respect of the certified product as described in the WaterMark Certificate of Conformity – Schedule of Certified Product (Refer also IAPMO Product Listing Directory). The Certificate is granted subject to the rules governing the WaterMark Certification Scheme and the Terms and Conditions of the Approved User Agreement and IAPMO Oceania's WaterMark Governance Rules.

Evaluated to:

AS/NZS 2638.2-2011

Gate valves for waterworks purposes - Resilient seated

Manufacturer:

Refer to Licence Holder

Licence No.: WM-032159

First Certified: 25 Jun 2021

Certification Date: 25 Sep 2024

Expiry Date: 24 Jun 2026

A handwritten signature in black ink, appearing to read "David Viola".

David Viola
Chief Executive Officer of the IAPMO Group

This WaterMark certification is for the period indicated herein and is void after the date shown above. Any change in material, manufacturing process, marking or design without having first obtained the approval of IAPMO Oceania, or any evidence of non-compliance with applicable Standards, Specifications or of inferior workmanship, may be deemed sufficient cause for revocation of this certification. Reproduction of or reference to this certificate for advertising purposes may be made only by specific written permission of IAPMO Oceania. This certificate can only be reproduced in its entirety. Any alteration of this certificate could be grounds for revocation of this certification.

"This certificate is issued by a JAS-ANZ accredited Conformity Assessment Body. The ABCB and JAS-ANZ do not in any way warrant, guarantee or represent that the product the subject of this Certificate conforms to the WaterMark Certification Scheme Rules, nor accepts any liability arising out of the use of the product. The ABCB disclaims to the extent permitted by law, all liability (including negligence) for claims of losses, expenses, damages and costs arising as a result of the use of the product(s) referred to in this Certificate."



WATERMARK CERTIFICATE OF CONFORMITY

SCHEDULE OF CERTIFIED PRODUCT



Certificate Holder
Acu-Tech Pty Ltd

A.B.N.:68 626 756 223
119 Kevin Road, Maddington, Perth, WA 6109 Australia

Manufacturer
Refer to Licence Holder

Standard
AS/NZS 2638.2-2011

Gate valves for waterworks purposes - Resilient seated

Licence No. WM-032159

Certification Date: 25 Sep 2024

Expiry Date: 24 Jun 2026

First Certified: 25 Jun 2021

Brand Name	Model Name	Model ID	Product Type	Product Description	Nominal Size	End Connection	Max Operating Temperature	Nominal Pressure	Material	Operating Mechanism
Acu-Flow	RSGV	GAT 80	Gate Valve	DN 80 Resilient Seated Gate Valve	DN 80	Flange X Flange	40° C	PN 16	Ductile Iron	Handwheel
Acu-Flow	RSGV	GAT100	Gate Valve	DN 100 Resilient Seated Gate Valve	DN 100	Flange X Flange	40° C	PN 16	Ductile Iron	Handwheel
Acu-Flow	RSGV	GAT150	Gate Valve	DN 150 Resilient Seated Gate Valve	DN 150	Flange X Flange	40° C	PN 16	Ductile Iron	Handwheel
Acu-Flow	RSGV	GAT200	Gate Valve	DN 200 Resilient Seated Gate Valve	DN 200	Flange X Flange	40° C	PN 16	Ductile Iron	Handwheel
Acu-Flow	RSGV	GAT250	Gate Valve	DN 250 Resilient Seated Gate Valve	DN 250	Flange X Flange	40° C	PN 16	Ductile Iron	Handwheel
Acu-Flow	RSGV	GAT300	Gate Valve	DN 300 Resilient Seated Gate Valve	DN 300	Flange X Flange	40° C	PN 16	Ductile Iron	Handwheel
Acu-Flow	RSGV	GAT 80E	Gate Valve	DN 80 Resilient Seated Gate Valve with AS2129 Table E Flange	DN 80	Flange X Flange	40° C	PN 14	Ductile Iron	Handwheel
Acu-Flow	RSGV	GAT100E	Gate Valve	DN 100 Resilient Seated Gate Valve with AS2129 Table E Flange	DN 100	Flange X Flange	40° C	PN 14	Ductile Iron	Handwheel
Acu-Flow	RSGV	GAT150E	Gate Valve	DN 150 Resilient Seated Gate Valve with AS2129 Table E Flange	DN 150	Flange X Flange	40° C	PN 14	Ductile Iron	Handwheel
Acu-Flow	RSGV	GAT200E	Gate Valve	DN 200 Resilient Seated Gate Valve with AS2129 Table E Flange	DN 200	Flange X Flange	40° C	PN 14	Ductile Iron	Handwheel
Acu-Flow	RSGV	GAT250E	Gate Valve	DN 250 Resilient Seated Gate Valve with AS2129 Table E Flange	DN 250	Flange X Flange	40° C	PN 14	Ductile Iron	Handwheel
Acu-Flow	RSGV	GAT300E	Gate Valve	DN 300 Resilient Seated Gate Valve with AS2129 Table E Flange	DN 300	Flange X Flange	40° C	PN 14	Ductile Iron	Handwheel

END RECORD

END RECORD

David Viola
Chief Executive Officer of the IAPMO Group